



# J. P. CENTRAL SCHOOL

(Run & Managed by : Janaki Educational Trust)

AFFILIATED TO C.B.S.E. NEW DELHI

AFF. Code : 330762

School No. : 65759

Ref. No. : 23/24  
To,

Date : 05/03/2024

The Sub Divisional Officer

PHED, Samastipur, Bihar

Sub:- Issue of No Objection certificate regarding safe drinking water and sanitary condition for our school **J.P. Central School**, At- Mathurapur Ghat, Samastipur-848101

Dear Sir,

I Request You to kindly issue a No Objection certificate for the above mentioned subject. The school have been pure, safe and purify water for drinking and sanitary condition is also good.

I will be highly obelised for this kind gesture of yours.

Thanking you

Manager  
J.P. Central School  
Mathurapur Samastipur

MATHURAPUR GHAT, SAMASTIPUR-848101 (BIHAR)

Ph. : 06274-251327, Mob. : 9430441288, 9709533102

Website : jpcentralschool.com E-mail : jpcs.director@gmail.com


Government of Bihar  
Public Health Engineering Department

DISTRICT :- SAMASTIPUR

DIVISION :- SAMASTIPUR

MONTH:-MARCH 2024

S.N.	BLOCK	PANCHAYAT	VILLAGE	LOCATION OF SOURCE	PARAMETERS									REMARKS
					pH	TURB	EC	TDS	TH	Cl	Alka.	Fe	T.COLI	
1	SAMASTIPUR	MATHURAPUR GHAT	MATHURAPUR GHAT	J.P CENTRAL SCHOOL MATHURAPUR GHAT	7.1	1	399	265	130	22	188	0.1	-ve	
Acceptable Limit as per BIS 10500/2012					6.5-8.5	1 NTU	-	500 mg/l	200 mg/l	250mg/l	200 mg/l	1.0mg/l		-
Permissible Limit* in absence of alternate source as per BIS 10500/2012					NR	5 NTU	-	2000 mg/l	600 mg/l	1000 mg/l	600 mg/l	NR		-

  
 09/03/24  
 CHEMIST  
 P.H.DIVISION SAMASTIPUR  
